Appendix B
UNDERGROUND ELECTRICAL SERVICES

1. All electrical services and cables are to be of the highest quality.

2. A plan must be supplied detailing the exact location and measurements of the underground electrical service.

3. Where an underground electrical service is to cross a constructed road:-
- (a) The trench to lay the electrical service is to be excavated so that the service will be at least 500mm below the water table or lowest elevation of the road.
- (b) The trench is to be thoroughly tamped, consolidated, backfilled and maintained to the satisfaction of Council.

4. Where an underground electrical service is to be laid along a road:-
- (a) The electrical service shall be at least 500mm below natural surface.
- (b) The alignment of the electrical service shall be as close to 600mm from the property boundaries as possible.
- (c) The service is to be at least 500mm below the invert of any stormwater drain to facilitate silt removal.
- (d) The trench is to be thoroughly tamped, consolidated, backfilled and maintained to the satisfaction of Council.

5. Council accepts no responsibility for damage to or by the electrical service however so arising and without in any way limiting the effect of this clause, including damage that may be caused by road maintenance and/or construction.

6. On change of ownership of the property, Council's aforesaid requirements and conditions still apply.